



CITY OF LODI

COUNCIL COMMUNICATION

AGENDA TITLE: Specifications and Advertisement for Bids for Watthour Meters

MEETING DATE: August 6, 1997

SUBMITTED BY: Electric Utility Director

RECOMMENDED ACTION: That the City Council approve the specifications and authorize the advertisement for bids for the purchase of 384 electric watthour meters.

BACKGROUND INFORMATION: The Electric Utility Department's Engineering Division has requested that 384 single-phase watthour meters be purchased to provide an inventory for installation of meters at new housing developments such as Bridgetown, Century Meadows, Sun West #14, and Towne Ranch #5, as well as for replacement of obsolete and deteriorated meters located during meter testing.

FUNDING: The estimated cost of this purchase is \$12,000. Funding is available in the Electric Utility Department's Operating Fund.

BID OPENING: August 20, 1997

A handwritten signature in cursive script, reading "Alan N. Vallow".

Alan N. Vallow, Electric Utility Director

Prepared by Joel Harris, Purchasing Officer

APPROVED: _____

A handwritten signature in cursive script, reading "H. Dixon Flynn".

H. DIXON FLYNN
City Manager

EQUIPMENT SPECIFICATIONS

WATTHOUR METERS

GENERAL

Meter shall be single-phase watthour with clock dial register, self-contained socket-type having glass cover. A label marked "City of Lodi" and a sequential number beginning with 34625 shall be factory installed on each meter. Shipping boxes shall show on the outside the sequential number of the meter contained therein.

RATING

Form 2S, 4 terminal, 240 volt, 3 wire, Class 200, 5 dials, Kh7.2, test amps 30, multiplying factor 1.

ACCEPTABLE BRANDS

Acceptable manufacturer-models are:	ABB Type D5S, Catalog #5570C10G10
	GE Type I-70, Catalog #720X070001
	Landis & Gyr Type MS, Catalog #9101-0056
	Schlumberger Type J5S, Catalog #96000